

October 26, 2004

LICENSEE: Exelon Generation Company

FACILITY: Dresden Nuclear Power Station, Units 2 and 3, and Quad Cities Nuclear Power Station, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 13, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND THE EXELON GENERATION COMPANY REGARDING THE RESOLUTION OF OPEN ITEM 3.5.2.3.2-1 AND CONFIRMATORY ITEM 3.0.3.14.2-1

On July 13, 2004, the U.S. Nuclear Regulatory Commission staff (the staff) and representatives from Exelon Generation Company held a telephone conference call to discuss the resolution of Open Item 3.5.2.3.2-1 and Confirmatory Item 3.0.3.14.2-1.

Enclosure 1 provides a listing of the telephone conference call participants. Enclosure 2 contains a listing of the Open Item 3.5.2.3.2-1 and Confirmatory Item 3.0.3.14.2-1. The applicant has had an opportunity to review this summary.

/RA/

Rajender Auluck, Senior Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-238, 50-249, 50-254 and 50-265

Enclosures: As stated

cc w/enclosures: See next page

October 26, 2004

LICENSEE: Exelon Generation Company

FACILITY: Dresden Nuclear Power Station, Units 2 and 3, and Quad Cities Nuclear Power Station, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 13, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND THE EXELON GENERATION COMPANY REGARDING THE RESOLUTION OF OPEN ITEM 3.5.2.3.2-1 AND CONFIRMATORY ITEM 3.0.3.14.2-1

On July 13, 2004, the U.S. Nuclear Regulatory Commission staff (the staff) and representatives from Exelon Generation Company held a telephone conference call to discuss the resolution of Open Item 3.5.2.3.2-1 and Confirmatory Item 3.0.3.14.2-1.

Enclosure 1 provides a listing of the telephone conference call participants. Enclosure 2 contains a listing of the Open Item 3.5.2.3.2-1 and Confirmatory Item 3.0.3.14.2-1. The applicant has had an opportunity to review this summary.

/RA/

Rajender Auluck, Senior Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-238, 50-249, 50-254 and 50-265

Enclosures: As stated

cc w/enclosures: See next page

ADAMS Accession No.: ML043010228

E:\Filenet\ML043010228.wpd

OFFICE:	PM:RLEP	PM:RLEP	LA:RLEP	SC:RLEP
NAME:	RAuluck	KCorp	MJenkins	SLee
DATE:	10/26/04	10/26/04	10/26/04	10/26/04

OFFICIAL RECORD COPY

LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE

July 13, 2004

Participants

William Burton
John Ma
Benjamin Wong
Rajender Auluck
Albert Fulvio
Rob Stachniak

Affiliation

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
NRC
Exelon
Exelon

**REVIEW OF LICENSE RENEWAL APPLICATION (LRA) FOR
DRESDEN UNITS 2 AND 3, AND QUAD CITIES UNITS 1 AND 2
DISCUSSION OF OPEN AND CONFIRMATORY ITEMS**

Open Item 3.5.2.3.2-1

The staff was unclear regarding the applicant's commitment to performing an inspection of Class MC pipe supports prior to the period of extended operation. In its letter dated June 22, 2004, the applicant revised Section B.1.30 of the LRA to include an enhancement to provide a VT-3 visual inspection of 15% of the non-exempt Class MC pipe supports once every 10 years. The staff found this acceptable. The applicant agreed to revise SER Appendix A, Item 30, "Structures Monitoring Program," to read "Existing program is credited." The program will be enhanced to add the following, which will be implemented prior to the period of extended operation:

The staff and applicant agreed that "implemented" in the revision means that the supports will be inspected prior to the period of extended operation. The staff's understanding will be documented in the SER.

Confirmatory Item 3.0.3.14.2-1

The staff and applicant agreed that Bullet (3) of SER Appendix A, Item 30, "Structures Monitoring Program," would be revised to clarify that standard components (e.g., snubbers, struts, and spring cans) will be inspected as part of the Structures Monitoring Program.

HARD COPY

RLEP RF
R. Auluck (PM)

E-MAIL:

RidsNrrDrip
RidsNrrDe
G. Bagchi
K. Manoly
W. Bateman
J. Calvo
R. Jenkins
P. Shemanski
J. Fair
RidsNrrDssa
RidsNrrDipm
D. Thatcher
R. Pettis
G. Galletti
C. Li
M. Itzkowitz (RidsOgcMailCenter)
R. Weisman
M. Mayfield
A. Murphy
S. Smith (srs3)
S. Duraiswamy
Y. L. (Renee) Li
RLEP Staff

L. Kozak, RIII
M. Ring, RIII

Dresden and Quad Cities Nuclear Power Stations

cc:

Site Vice President - Dresden Nuclear Power Station
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Dresden Nuclear Power Station Plant Manager
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Regulatory Assurance Manager - Dresden
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

U.S. Nuclear Regulatory Commission
Dresden Resident Inspectors Office
6500 N. Dresden Road
Morris, IL 60450-9766

Chairman
Grundy County Board
Administration Building
1320 Union Street
Morris, IL 60450

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4351

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West
Boiling Water Reactors
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden,
Quad Cities and Clinton
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Site Vice President - Quad Cities Nuclear
Power Station
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Quad Cities Nuclear Power Station
Plant Manager
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Dresden and Quad Cities Nuclear Power Stations -2-

cc:

Regulatory Assurance Manager - Quad
Cities
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Mr. Christopher M. Crane
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Quad Cities Resident Inspectors Office
U.S. Nuclear Regulatory Commission
22712 206th Avenue N.
Cordova, IL 61242

David C. Tubbs
Nuclear Resources Manager
MidAmerican Energy Company
One River Center Place
106 E. Second St.
Davenport, IA 52801

Vice President - Law and Regulatory Affairs
MidAmerican Energy Company
One River Center Place
106 E. Second Street
P.O. Box 4350
Davenport, IA 52808

Chairman
Rock Island County Board of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, IL 61201

Mr. Fred Emerson
Manager - License Renewal Program
Nuclear Energy Institute
1776 I Street, NW., Suite 400
Washington, DC 20006-3708

Exelon Generation Company, LLC
200 Exelon Way, KSA 1-N-3
Kennett Square, PA 19348

Sr. Engineer - License Renewal Program
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555